

GT595 software update V5.5 onwards

Following our last communication regarding the upgrade of the Gardtec 595 control panel from V5.2 to V5.5, the V5.5 control panels are now available. Please read below for the new and changed features.

New Features

- One software for all 595 panels 1.2 and 2 Amp
- View Panel Details in Service Menu: Details of the panel type, the firmware version number, the selected standard (BS/EN2 or EN3) are now displayed in the Service menu.

- PSU Auto Detect

The s/w is now able to check whether the panel is a linear or switch mode supply. There is now only one version of firmware for both the linear and switch mode panels.

- View Codes - It is now possible to view used code locations within the program user codes menu.

Changes

- PSU Defaults

Aux Volts Min changed from: 13V to: 12.6V, On-Charge Volts Min changed from: 12.5 to: 11.8V
Off-Charge Volts Min changed from: 12.5 to: 11.8V.

- Vocom is stopped when user code entered
- Gardtec Remote version 2.18 is now released

You will need to download the complete Gardtec Remote package to update your installation.

PLEASE NOTE: Program Transfer Modules saved data (PTM, Product Code 77023) can only be 'restored' into a panel (Load Panel NVM from PTM) holding the program settings for the same panel type and version.

Please exercise caution when using the PTM with mixed version control panels.

Also, the additional diode pack we provisionally added to alleviate keypad corruption on a small percentage of panels has now been removed due to a permanent fix made on the PCB.

If you have any queries on the above please feel free to contact the Technical department:

Tel: 0161 655 5600

technical@riscogroup.co.uk